

# TYPE TEST REPORT

## OPzS CELLS AND BLOCK BATTERIES

According to IEC 60896-11



**U-POWER BATTERIES, 66 Tzar Asen Srt, Sofia, Republic of Bulgaria**

Report Type	Type Test acc. to IEC 60896-11, DIN 40736 & DIN 40737
Product Type	OPzS cells and block batteries

Date	Iss. by	Appr. by	Lang.	Doc. Nr.
09/04/2013	Julio	Javier	EN	15.167.0021.00

## **INDEX**

OPzS Type Test Report.....	3
1 Discharge Capacity.....	4
1.1 2V - OPzS 50Ah Plate .....	5
1.2 6V - OPzS 50Ah Plate .....	10
1.3 12V - OPzS 50Ah Plate.....	15
1.4 70Ah Plate .....	20
1.5 100Ah Plate.....	25
1.6 125Ah Plate.....	30
2 Short Circuit Current & DC Internal Resistance.....	35
3 Charge Retention during Storage .....	36
4 Cycle life test (Endurance in Discharge – Charge Cycles).....	37
5 Suitability for Floating Operations.....	38
6 Service Life Test (at 60 °C) .....	40

### OPzS Type Test Report

This test report applies to all Upower's OPzS cells and monobloc batteries of the vented type for float charge applications, (i.e. permanently connected to a load and to a d.c. power supply), in a static location (i.e. not generally intended to be moved from place to place) and incorporated into stationary equipment or installed in battery rooms for use in telecom, uninterruptible power supply (UPS), utility switching, emergency power or similar applications and also solar applications.

Table 1 shows the relation between the test type and the number of cells acc. to IEC60896-11. The selection of the cell type Vs the test type was made in order to be able to extrapolate the results to the whole OPzS range. In most cases, the selection was made by the possible worst case scenario.

Test Clause According to IEC60896-11	Samples per Test
14. Capacity (240 h, 120h, 48h, 10 h, 8 h, 3 h, 1 h, 0,5 h)	6
15. Suitability for floating battery operation	6
16. Endurance in cycles	6
17. Endurance in overcharge	6
18. Charge retention	3
19. Short-circuit current and internal resistance	3

**Table 1 – Test type Vs Cell Type acc. to IEC 60896-11**

Some extra tests have been added by UPOWER and are presented below:

Extra Tests	Samples per Test
Impact of stress temperature of 55°C or 60°C (as per IEC 60896-21, clause 6.16)	3

**Table 2 – Supplementary type tests**

## 1 Discharge Capacity.

The purpose of this test is to confirm the capacity of the cells/batteries to a specific end-voltage at the selected discharge rate. One cell type per 50Ah, 70Ah, 100Ah and 125Ah plate has been selected. Regarding the 50Ah plate, the tests have been separated into two categories:

- 2V cells
- Monoblock batteries

The reason for this categorization is the difference of the separator for these two types (the plate remains the same but the monoblock batteries are using thinner separator comparing to the 2V cells).

Each cell type was tested at the following rates:

Rate	C0,25	C1	C3	C8	C10	C20	C48	C120
Temperature (°C)	20	20	20	20	20	20	20	20
Final Voltage (V/cell)	1,6	1,6	1,7	1,75	1,8	1,8	1,8	1,85

**Table 3 – Discharge rates and end voltages**

The most common applications for the U-POWER OPzS batteries are:

<b>UPOWER OPzS Batteries Applications</b>	<b>Low Discharge Rate</b>	<b>Medium Discharge Rate</b>	<b>High Discharge Rate</b>
Telecommunications	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Control and monitoring systems in power plants and distribution stations	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Railway, airport and seaport signalling	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency lighting	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Data processing systems	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Automation	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Renewable energy systems (solar, wind, hydro)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**Table 4 – UPOWER OPzS batteries applications**

Deviation according to IEC: cells have been submitted initially to two C10 discharges (IEC mentions that the cells shall not have been previously submitted to any discharges). In any case, the results from the two initial discharges were successful with the actual capacity to be  $\geq 95\%$  of the rated capacity.

**1.1 2V - OPzS 50Ah Plate**


Instruction: IEC 60896-11, clause 14  
 Test items: 6pcs, 2V - 5 OPzS 250  
 Specification: Actual Capacity Vs Rated Capacity  $C_a \geq 95\%$  Crt at 1<sup>st</sup> cycle and  $C_a \geq 100\%$  Crt at 5<sup>th</sup> cycle  
 Test Result: **Successful**

5 OPzS 250								
Rate	C0,25	C1	C3	C8	C10	C20	C48	C120
Current (A)	330,2	148,6	68,8	32,9	27	15,6	7,47	3,15
Final Voltage (V)	1,6	1,6	1,7	1,75	1,8	1,8	1,8	1,85
Test Temperature (°C)	20	20	20	20	20	20	20	20
Nominal Capacity (Ah)	82,6	148,6	206,4	263,2	270,0	312,0	358,6	378,0
Measured Capacity (Ah)	97,29	168,46	229,52	282,14	288,80	333,86	379,47	396,74
Nominal Capacity (50 Ah Plate)	16,5	29,7	41,3	52,6	54,0	62,4	71,7	75,6
Measured Capacity (50 Ah Plate)	19,46	33,69	45,90	56,43	57,76	66,77	75,89	79,35
<b>Result (%)</b>	<b>117,9%</b>	<b>113,4%</b>	<b>111,2%</b>	<b>107,2%</b>	<b>107,0%</b>	<b>107,0%</b>	<b>105,8%</b>	<b>105,0%</b>


**Table 5 – Summary of test results for the 2V – 5 OPzS 250**

**Summary of test results:** Tests were successful. In all the rates the following was applied  $C_a \geq 100\%$  Crt


The measurement curves are shown below:




**Figure 1. C0.25 Capacity Test**




**Figure 2.** C1 Capacity Test



**Figure 3.** C3 Capacity Test



**Figure 4.** C8 Capacity Test



**Figure 5.** C10 Capacity Test




Figure 6. C20 Capacity Test





Figure 7. C48 Capacity Test





**Figure 8.** C120 Capacity Test

**1.2 6V - OPzS 50Ah Plate**


Instruction: IEC 60896-11, clause 14  
 Test items: 6pcs, 6V - 6 OPzS 300  
 Specification: Actual Capacity Vs Rated Capacity  $C_a \geq 95\%$  Crt at 1<sup>st</sup> cycle and  $C_a \geq 100\%$  Crt at 5<sup>th</sup> cycle  
 Test Result: **Successful**

6V - 6 OPzS 300								
Rate	C0,25	C1	C3	C8	C10	C20	C48	C120
Current (A)	373,7	181,6	82,6	38,5	31,2	17,69	8,28	3,40
Final Voltage (V)	4,8	4,8	5,1	5,25	5,4	5,4	5,4	5,55
Test Temperature (°C)	20	20	20	20	20	20	20	20
Nominal Capacity (Ah)	93,4	181,6	247,8	308,0	312,0	353,8	397,4	408,0
Measured Capacity (Ah)	108,03	190,78	262,57	320,11	318,82	363,69	408,97	419,89
Nominal Capacity (50 Ah Plate)	15,6	30,3	41,3	51,3	52,0	59,0	66,2	68,0
Measured Capacity (50 Ah Plate)	18,00	31,80	43,76	53,35	53,14	60,61	68,16	69,98
<b>Result (%)</b>	<b>115,6%</b>	<b>105,1%</b>	<b>106,0%</b>	<b>103,9%</b>	<b>102,2%</b>	<b>102,8%</b>	<b>102,9%</b>	<b>102,9%</b>

**Table 6 – Summary of test results for the 6V – 6 OPzS 300**

**Summary of test results:** Tests were successful. In all the rates the following was applied  $C_a \geq 100\%$  Crt

The measurement curves are shown below:



**Figure 9.** C0.25 Capacity Test




Figure 10. C1 Capacity Test




Figure 11. C3 Capacity Test




Figure 12. C8 Capacity Test




Figure 13. C10 Capacity Test




Figure 14. C20 Capacity Test





Figure 15. C48 Capacity Test



**Figure 16.** C120 Capacity Test

**1.3 12V - OPzS 50Ah Plate**


Instruction: IEC 60896-11, clause 14  
 Test items: 6pcs, 12V - 2 OPzS 100  
 Specification: Actual Capacity Vs Rated Capacity  $C_a \geq 95\%$  Crt at 1<sup>st</sup> cycle and  $C_a \geq 100\%$  Crt at 5<sup>th</sup> cycle  
 Test Result: **Successful**

12V - 2 OPzS 100								
Rate	C0,25	C1	C3	C8	C10	C20	C48	C120
Current (A)	139,3	64,2	28,3	12,75	10,3	5,74	2,66	1,10
Final Voltage (V)	9,6	9,6	10,2	10,5	10,8	10,8	10,8	11,1
Test Temperature (°C)	20	20	20	20	20	20	20	20
Nominal Capacity (Ah)	34,8	64,2	84,9	102,0	103,0	114,8	127,7	132,0
Measured Capacity (Ah)	36,29	65,71	85,53	103,19	104,82	119,17	133,75	133,61
Nominal Capacity (50 Ah Plate)	17,4	32,1	42,5	51,0	51,5	57,4	63,8	66,0
Measured Capacity (50 Ah Plate)	18,15	32,85	42,77	51,60	52,41	59,59	66,87	66,81
<b>Result (%)</b>	<b>104,2%</b>	<b>102,3%</b>	<b>100,7%</b>	<b>101,2%</b>	<b>101,8%</b>	<b>103,8%</b>	<b>104,8%</b>	<b>101,2%</b>

**Table 7 – Summary of test results for the 12V – 2 OPzS 100**

**Summary of test results:** Tests were successful. In all the rates the following was applied  $C_a \geq 100\%$  Crt

The measurement curves are shown below:



**Figure 17. C0.25 Capacity Test**




Figure 18. C1 Capacity Test




Figure 19. C3 Capacity Test






Figure 20. C8 Capacity Test




Figure 21. C10 Capacity Test




Figure 22. C20 Capacity Test





Figure 23. C48 Capacity Test



**Figure 24.** C120 Capacity Test

**1.4 70Ah Plate**


Instruction: IEC 60896-11, clause 14  
 Test items: 6pcs 2V - 6 OPzS 420  
 Specification: Actual Capacity Vs Rated Capacity  $C_a \geq 95\%$  Crt at 1<sup>st</sup> cycle and  $C_a \geq 100\%$  Crt at 5<sup>th</sup> cycle  
 Test Result: **Successful**

2V - 6 OPzS 420								
Rate	C0,25	C1	C3	C8	C10	C20	C48	C120
Current (A)	516,5	265,9	122,8	58,5	47,4	27,4	13,13	5,51
Final Voltage (V)	1,6	1,6	1,7	1,75	1,8	1,8	1,8	1,85
Test Temperature (°C)	20	20	20	20	20	20	20	20
Nominal Capacity (Ah)	129,1	265,9	368,4	468,0	474,0	548,0	630,2	661,2
Measured Capacity (Ah)	153,47	292,09	383,65	481,01	502,29	573,52	649,37	675,07
Nominal Capacity (70 Ah Plate)	21,5	44,3	61,4	78,0	79,0	91,3	105,0	110,2
Measured Capacity (70 Ah Plate)	25,58	48,68	63,94	80,17	83,72	95,59	108,23	112,51
<b>Result (%)</b>	<b>118,9%</b>	<b>109,9%</b>	<b>104,1%</b>	<b>102,8%</b>	<b>106,0%</b>	<b>104,7%</b>	<b>103,0%</b>	<b>102,1%</b>

**Table 8 – Summary of test results for the 2V – 6 OPzS 420**

**Summary of test results:** Tests were successful. In all the rates the following was applied  $C_a \geq 100\%$  Crt

The measurement curves are shown below:



**Figure 25. C0.25 Capacity Test**




Figure 26. C1 Capacity Test




Figure 27. C3 Capacity Test




Figure 28. C8 Capacity Test







Figure 29. C10 Capacity Test



**Figure 30.** C20 Capacity Test



**Figure 31.** C48 Capacity Test



**Figure 32.** C120 Capacity Test



**1.5 100Ah Plate**


Instruction: IEC 60896-11, clause 14  
 Test items: 6pcs 2V - 6OPzS600  
 Specification: Actual Capacity Vs Rated Capacity  $C_a \geq 95\%$  Crt at 1<sup>st</sup> cycle and  $C_a \geq 100\%$  Crt at 5<sup>th</sup> cycle  
 Test Result: **Successful**

2V - 6 OPzS 600								
Rate	C0,25	C1	C3	C8	C10	C20	C48	C120
Current (A)	656,6	378,1	175	83,6	67,2	39,4	19,07	8,05
Final Voltage (V)	1,6	1,6	1,7	1,75	1,8	1,8	1,8	1,85
Test Temperature (°C)	20	20	20	20	20	20	20	20
Nominal Capacity (Ah)	164,2	378,1	525,0	668,8	672,0	788,0	915,4	966,0
Measured Capacity (Ah)	231,9	400,5	563,8	688,6	700,0	814,9	925,0	979,8
Nominal Capacity (100 Ah Plate)	27,4	63,0	87,5	111,5	112,0	131,3	152,6	161,0
Measured Capacity (100 Ah Plate)	38,66	66,75	93,97	114,76	116,67	135,81	154,17	163,30
<b>Result (%)</b>	<b>141,3%</b>	<b>105,9%</b>	<b>107,4%</b>	<b>103,0%</b>	<b>104,2%</b>	<b>103,4%</b>	<b>101,1%</b>	<b>101,4%</b>

**Table 9 – Summary of test results for the 2V – 6OPzS600**

**Summary of test results:** Tests were successful. In all the rates the following was applied  $C_a \geq 100\%$  Crt

The measurement curves are shown below:



**Figure 33. C0.25 Capacity Test**




Figure 34. C1 Capacity Test






Figure 35. C3 Capacity Test



**Figure 36.** C8 Capacity Test



**Figure 37.** C10 Capacity Test




Figure 38. C20 Capacity Test




Figure 39. C48 Capacity Test




Figure 40. C120 Capacity Test

**1.6 125Ah Plate.**


Instruction: IEC 60896-11, clause 14  
 Test items: 6pcs 2V - 24 OPzS 3000  
 Specification: Actual Capacity Vs Rated Capacity  $C_a \geq 95\%$  Crt at 1<sup>st</sup> cycle and  $C_a \geq 100\%$  Crt at 5<sup>th</sup> cycle  
 Test Result: **Successful**

2V - 24 OPzS 3000								
Rate	C0,25	C1	C3	C8	C10	C20	C48	C120
Current (A)	2966	1861	877,7	418	336,1	194,5	92,3	38,50
Final Voltage (V)	1,6	1,6	1,7	1,75	1,8	1,8	1,8	1,85
Test Temperature (°C)	20	20	20	20	20	20	20	20
Nominal Capacity (Ah)	741,5	1861,0	2633,1	3344,0	3361,0	3890,0	4430,4	4620,0
Measured Capacity (Ah)	849,1	1928,6	2786,0	3453,9	3480,7	3979,5	4544,9	4789,2
Nominal Capacity (125 Ah Plate)	30,9	77,5	109,7	139,3	140,0	162,1	184,6	192,5
Measured Capacity (125 Ah Plate)	35,38	80,36	116,08	143,91	145,03	165,81	189,37	199,55
<b>Result (%)</b>	<b>114,5%</b>	<b>103,6%</b>	<b>105,8%</b>	<b>103,3%</b>	<b>103,6%</b>	<b>102,3%</b>	<b>102,6%</b>	<b>103,7%</b>

**Table 10 – Summary of test results for the 2V – 6 OPzS 420**

**Summary of test results:** Tests were successful. In all the rates the following was applied  $C_a \geq 95\%$  Crt

The measurement curves are shown below:



**Figure 41. C0.25 Capacity Test**




Figure 42. C1 Capacity Test




Figure 43. C3 Capacity Test




Figure 44. C8 Capacity Test




Figure 45. C10 Capacity Test






Figure 46. C20 Capacity Test




Figure 47. C48 Capacity Test




Figure 48. C120 Capacity Test

## **2 Short Circuit Current & DC Internal Resistance**

The purpose of this test is to define prospective short-circuit value  $I_{sc}$  and internal resistance  $R_i$  of the specific OPzS units. The short circuit current is defined by determining two data pairs in the following way:

### **a. First data pair ( $U_a$ , $I_a$ )**

After 20 s of discharge at the current  $I_a = 4 \times I_{10}$ , the voltage and current shall be recorded to give the first data pair. The current shall be interrupted after 25 s maximum and, without recharge and after an open circuit stand of 5 min, the second data pair shall be determined.

### **b. Second data pairs ( $U_b$ , $I_b$ )**

After 5 s of discharge at the current  $I_b = 20 \times I_{10}$ , the voltage and current shall be recorded to give the second data pair.

Instruction: IEC 60896-11, clause 6.3

Test items: 3pcs 2V - 5 OPzS 250, 3pcs 12V - 2 OPzS 100, 3pcs 6V - 6 OPzS 300, 3pcs 2V - 6 OPzS 420, 3pcs 2V - 6OPzS600 & 3pcs 2V - 24 OPzS 3000

Specification: values must be  $\pm 10\%$  of the specification values

Temperature: 20°C

Test Result: **Successful**

The results are shown on the table below:

Cell type	Cnom (Ah) DIN values	I1 (A)	I2 (A)	U1 at 20sec (V)	U2 at 5sec (V)	Ri-test (mΩ)	Isc-test (A)	Ri-spec $\pm 10\%$ (mΩ)	Isc-spec $\pm 10\%$ (A)	Ri-test Vs. spec	Isc-test Vs. spec
<b>2V 5 OPzS 250</b>	250	100	500	1,957	1,710	0,618	3269	0,671	3000	92,0%	109,0%
<b>2V 6 OPzS 420</b>	420	168	840	1,943	1,620	0,481	4210	0,518	3900	92,9%	108,0%
<b>2V 6 OPzS 600</b>	600	240	1200	1,911	1,501	0,427	4715	0,447	4500	95,7%	104,8%
<b>2V 24 OPzS 3000</b>	3000	1200	6000	1,882	1,385	0,104	19376	0,108	18800	96,3%	103,1%
<b>12V 2 OPzS 100</b>	100	40	200	11,67	10,23	9,03	1332	9,679	1260	93,3%	105,7%
<b>6V 6 OPzS 300</b>	300	120	600	5,775	4,865	1,90	3166	2,000	3040	94,8%	104,1%

**Table 11 – Rint & Isc Results**

### 3 Charge Retention during Storage

The purpose of this requirement is to show the residual dischargeable capacity Cr after storage on open circuit under defined conditions of temperature and time.

Instruction: IEC 60896-11, clause 18


Test items: 6pcs 2V - 6 OPzS 420

Result: **Successful. Capacity reduction is less than 2,5% per month**

Test procedure: After having undergone the initial capacity test (Ca1), the battery is fully recharged, thoroughly cleaned and then is being stored on open circuit at an average cell temperature of 20 °C ± 2 °C for a period of 90 days. During that time, the maximum cell temperature does not exceed +25 °C and the minimum temperature is not less than +15 °C. At the end of the open circuit storage the residual capacity is determined.

Results:

		initial	residual
Cell type	2V 6 OPzS 420		
Test samples	6 cells		
Discharge rate	C10		
Rated capacity (Cr)	420 Ah		
Rated current (Ir)	42 A		
Cut off voltage (Uf)	1,80 Vpc		
Test initial temper. (To)		19 oC	20 oC
Average test current (I)		42 A	42 A
Discharge time (t)		705 min	665 min
Test capacity (C)		494 Ah	466 Ah
Capacity at 20°C		496 Ah	466 Ah
Capacity at 20°C %		<b>118,2%</b>	<b>110,8%</b>
Capacity reduction in 3 months %		<b>7,38%</b>	
Capacity reduction per month %		<b>2,46%</b>	



**Figure 49.** Capacity test before and after the storage period


#### 4 Cycle life test (Endurance in Discharge – Charge Cycles)

The purpose of the test is to measure the endurance in discharge-charge cycles for applications where frequent discharges of the battery are to be encountered due either to a deliberate choice of operational or to frequent power-line outages.

Instruction: IEC 60896-11, clause 16  
 Test items: 6pcs, 2V – 6 OPzS 420  
 Test Result: **1520 cycles to reach 80% C10**

Test procedure: The test was performed under the following profile:

- Capacity test settings: 10h rate at 1.80V/c according DIN capacity and current values (C10=420Ah, I10=42A). Capacity is implemented after an equalizing charge
- Discharge cycling settings: Discharge with 2.0 x I10 for 3 hours. This current corresponds to ~4h discharge DIN rate. The 3h discharge out of 4h nominal yields 75% DoD for each cycle.
- Recharge the battery for 21h at 2.40 ± 0.01 V/cell
- Nominal electrolyte density is 1.240 ± 0.010 gr/ml at 20°C
- Nominal single cell voltage deviation is -50 to +100mV from the average battery voltage
- During test, the electrolyte temperature is 25± 5 °C



**Figure 50.** Capacity Vs Cycles

## 5 Suitability for Floating Operations

The purpose of the test is to check the suitability of the cells or batteries in this operation.

A battery in floating operation has a constant voltage, permanently applied to its terminal which is sufficient to maintain it in a state close to full charge and is intended to supply a circuit whose normal power supply may fail.

Test items: 6pcs, 2V – 6 OPzS 420

Test Result: **Successful. The cells retained their capacity, voltage and density values within nominal range without water loss**

Test procedure: The cells are kept at an ambient temperature close to 20 °C. The upper surface of the cells (lids) was kept clean and dry throughout the test. The cells were submitted to a permanent floating charge at a voltage 2.23Vpc. After intervals of three months, the voltage and the electrolyte density of each cell and the level of the electrolyte were measured and noted. After six months of battery floating operation, the cells were subjected to a capacity test at 10h DIN rate. The following rules and settings have been observed:

- Nominal floating voltage for the battery is  $2.23 \pm 1\%$  V/cell
- Nominal electrolyte density is  $1.240 \pm 0.010$  gr/ml at 20°C
- Nominal single cell voltage deviation is -50 to +100 mV from the average battery voltage
- During test, the electrolyte temperature is  $20 \pm 5$  °C

### Results:

Densities (gr/ml at 20°C)										Variation from average	
cell	1	2	3	4	5	6	Average	Minimum	Maximum	to Minimum	to Maximum
initial	1,240	1,239	1,240	1,240	1,239	1,239	1,240	1,239	1,24	0,000	0,000
at 3 months	1,242	1,24	1,242	1,243	1,241	1,241	1,242	1,24	1,243	-0,002	0,002
at 6 months	1,243	1,241	1,242	1,244	1,242	1,244	1,242	1,241	1,244	-0,001	0,002

Conclusion: Densities remain within nominal values


Float voltage (Volts)										Variation from average	
cell	1	2	3	4	5	6	Average	Minimum	Maximum	to Minimum	to Maximum
initial	2,205	2,251	2,265	2,258	2,21	2,201	2,232	2,201	2,265	-0,031	0,033
at 3 months	2,212	2,236	2,262	2,251	2,212	2,205	2,230	2,205	2,262	-0,025	0,032
at 6 months	2,221	2,235	2,254	2,246	2,222	2,221	2,233	2,221	2,254	-0,012	0,021

Conclusion: Float voltages remain within nominal values

Water consumption (mm from MAX level)										Variation from average	
cell	1	2	3	4	5	6	Average	Minimum	Maximum	to Minimum	to Maximum
initial	MAX	MAX	MAX	MAX	MAX	MAX	MAX	MAX	MAX	not detected	not detected
at 3 months	MAX	MAX	MAX	MAX	MAX	MAX	MAX	MAX	MAX	not detected	not detected
at 6 months	MAX	MAX	MAX	MAX	MAX	MAX	MAX	MAX	MAX	not detected	not detected

Conclusion: No water loss was detected within 6 months

		initial	after 6 months
Cell type	2V 2 OPzS 250	21 oC	19 oC
Test samples	6 cells	42 A	42 A
Discharge rate	C10	658 min	667 min
Rated capacity (Cr)	250 Ah	274 Ah	278 Ah
Rated current (Ir)	25 A	273 Ah	280 Ah
Cut off voltage (Uf)	1,80 Vpc	<b>109,0%</b>	<b>111,8%</b>
		<b>2,8%</b>	



**Figure 51.** Capacity test before and after the floating period

## 6 Service Life Test (at 60 °C)

The purpose of the test is to define the expected lifetime of the battery under normal service conditions (floating voltage of 2.23 V/c and temperature 20 °C).

The parameter that is used to accelerate the test is the temperature. The batteries are subjected to the normal floating voltage but at a much higher temperature (60 °C).

The acceleration factor to extrapolate the service life at 20°C from the achieved duration at 60°C is the value that corresponds to the halving of the lifetime for every 9°K temperature rise.

$$F_{(60vs20)} = 2^{[(60-20)/9]} = 21.77 \text{ times}$$

$$\text{LifeTime at } 20^{\circ}\text{C} = \text{LifeTime at } 60^{\circ}\text{C} \times 21.77$$

Test items: 6pcs, 2V – 6 OPzS 420

Test Result: **Days at 60°C: 472.8**

**Equivalent Service Life at 20°C: 28.2 years**


Test procedure: The batteries are subjected to the test conditions for periods of 30 days each. After the end of each period a discharge test was applied in order to measure the available capacity under the following conditions:

- a. 10h capacity test at 1.80V/cell at 20°C (DIN values)
- b. Full charge before and after a capacity test
- c. The end-of-test criteria is the capacity drop below 80% of the DIN nominal value

### Results - 6 cells 6 OPzS 420

Days at 60°C achieved: 472.8 days

Equivalent service life at 20°C: 28.2 years



**Figure 52.** Days vs Capacity