



Product Service

Attestation of Conformity

No. N8A 121060 0004 Rev. 00

Holder of Attestation: **MASTER BATTERY, S.L.**
PASEO DE EXTREMADURA, 39
28935 MOSTOLES
SPAIN

Product: **Converter**
(Hybrid inverter)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290233041801

Date, 2023-06-06

(Billy Qiu)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

**TUV®**



Product Service

Attestation of Conformity

No. N8A 121060 0004 Rev. 00

Model(s): MF-GREENE-3.68K, MF-GREENE-5K, MF-GREENE-6K

Parameters:

Model	MF-GREENE-3.68K	MF-GREENE-5K	MF-GREENE-6K
PV terminal			
Vmax. PV	580Vd.c.		
Rated Voltage	400Vd.c.		
MPPT Voltage Range	80~560Vd.c.		
MPPT Voltage Range (full load)	165 ~ 520Vd.c.	210 ~ 520Vd.c.	250 ~ 520Vd.c.
MPPT Tracker number	2		
Max. continuous PV input current per tracker	15Ad.c.		
Isc PV per tracker	18Ad.c.		
Max. continuous PV input power	4800W	6500W	7500W
Battery terminal			
Battery type	Lithium or lead-acid battery		
Voltage range	40~60Vd.c.		
Rated voltage	48Vd.c.		
Maximum charge/discharge current	50Ad.c./80Ad.c.	100Ad.c./100Ad.c.	
Maximum charge/discharge power	3000W/4000W	4600W/5000W	
Grid terminal parameter			
Rated voltage	230Va.c.		
Rated frequency	50/60Hz		
Maximum continuous input current	32Aa.c.		
Maximum continuous input power	7360VA		
Maximum continuous output current	16Aa.c.	22Aa.c.	25Aa.c.
Maximum continuous output power	3680W	5000W	6000W
Maximum output apparent power	3680VA	5000VA	6000VA
Power factor (Cos phi), adjustable	0.8 leading~0.8 lagging		
Back up load terminal parameter			
Rated voltage	230Va.c.		
Rated frequency	50/60Hz		
Maximum continuous output current	16Aa.c.	20Aa.c.	
Rated continuous output power	3680W	4600W	
Maximum output apparent power	4000VA	5000VA	
General parameter			
Temperature	-25°C to +60°C, derating above 45 °C		
Protective class	Class I		
Overvoltage Category	II(DC side), III(AC side)		
Ingress protection	IP65		
Altitude	≤ 2000m		

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 121060 0004 Rev. 00

**Tested
according to:**

EN 62109-1:2010
EN 62109-2:2011

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®